

**LINCOLN WATER SYSTEM**  
Listing of Approved Cross Connection Control Assemblies  
**January 1<sup>st</sup>, 2004**

**Double Check Valve Backflow Prevention Assemblies**

Conbraco	4-S-100 (Model DC)	2 ½" thru 10"
	40-100	½" thru 10"
Febco	850	½" Thru 10"
	870 N or V Shape	2 ½" thru 10"
Hersey Beeco	Model FDC	¾" thru 2"
	Model # 2	3" thru 10"
Watts	709	3"-10"
	757a	2 ½" thru 6"
	757na	2 ½" thru 6"
	007 M2-QT	¾" thru 10"
Wilkins	950	¾" thru 10"
	350	2 ½" thru 8"
Ames	2000 SS (Fire Line Only)	3" thru 12"
	Colt 200a	2 ½" thru 6"
	Colt 200na	2 ½" thru 6"

**Reduced Pressure Principle Assemblies**

Conbraco	40-200	½" thru 10"
Febco	860	½" thru 10"
	825Y	¾" thru 2"
	880 N or V Shape	2 ½" thru 10"
Hersey Beeco	FRP-II	¾" thru 2"
Watts	909	¾" thru 10"
	009 M2	½" thru 3"
Wilkins	975 XL	¼" thru 2"
	975	¾" thru 10"
	375	2 ½" thru 8"

**Pressure Vacuum Breakers**

Conbraco	40-500	½" thru 2"
Febco	765	½" thru 2"
Watts	800QT	½" thru 2"
Wilkins	720A	½" thru 2"

**NOTE:** Only backflow preventers on this list are approved for installation by Lincoln Water System. All backflow preventers are to be installed in the horizontal position. All installations must be approved by the Lincoln Water System. (2 ½" assemblies cannot be used in containment installations, however they may be used in Isolation installations.)  
approved\_bfp04Jan.wpd